

# CITY OF MOUNTAIN VIEW

Finance and Administrative Services Department · Purchasing Division  
500 Castro Street · Post Office Box 7540 · Mountain View, California 94039-7540 · 650-903-6324 · FAX 650-968-5472

August 5, 2009

RE: PROPOSAL NO. R10 Childcare Fence Extension

## ADDENDUM NUMBER TWO

This addendum is issued to change parts of the specifications. Attached are the list of changes, a revised drawing and answers to Preproposal Conference Questions.

This addendum must be signed below acknowledging receipt and returned with the completed proposal.

Sincerely,

Ellen Boyd  
Buyer

\_\_\_\_\_  
Signature of Officer  
signifying receipt and understanding of  
this addendum

\_\_\_\_\_  
Date

### **CHANGES TO THE SPECIFICATIONS**

Time of Completion: The Contractor shall diligently prosecute the work to completion before the expiration of forty-five (45) calendar days from the date of Notice to Proceed.

Hours of Construction: Contractor shall be prohibited from working each day at the site from 10:00 am to 11:00 am and from 4:00 pm to 6:00 pm. All other hours shall be in accordance with the Specifications and Bid document.

Item 1: Section 02820 Chain Link Fencing,


- A. Part 2, Item 2.2A. Revise last sentence to read "Fabric shall be knuckled top and bottom, single width fabric to full height of fence extension.
- B. Part 2, Delete Item 2.11A, Windscreen..
- C. Part 3, Delete Item 3.4A Windscreen.

Item 2: Section 02821, Part 2, Item 2.3E. Revise last sentence to read "Color - Bronze to match existing."

### **CHANGES TO THE DRAWINGS**

Item 3: Revise sheet A.05 Chain link Fence per sheet AD1-01 attached to this addendum.

**END OF ADDENDUM #2**



**BILL GOULD DESIGN**  
ART & ARCHITECTURE

394-A Umberger Rd.  
San Jose, CA 95111  
Fax 408.224.9891  
Phone 408.224.9890

## CHAINLINK FENCE

**MOUNTAIN VIEW  
HAND BALL COURT  
CITY OF MOUNTAIN VIEW**

SCALE  
N.T.S.

ADDENDUM NO.  
1

PROJECT.#  
81015.05

REFERENCE

DATE  
07.30.09

A.05

ADDENDUM DRAWING SHEET NO.

**AD1.01**

### **QUESTIONS FROM PREPROPOSAL CONFERENCE**

Question 1: Is the artwork on the fence to remain?

Answer: The (E) artwork will remain and must be protected throughout the course of construction.

Question 2: Is there any scope related to the Large Art Gate facing the park?

Answer: You will be attaching the extensions to the (E) posts but that will be the only work done at the art gate.

Question 3: Is plexiglass to remain?

Answer: Any plexiglass that is currently installed on gates and/or fences shall be replaced with the new work. The only exception to this is the plexiglass installed on the Art Gate mentioned above. That plexiglass is to remain.

Question 4: Does the existing fence need to be repainted/refinished?

Answer: The existing fence will remain as is with the exception of any touch ups required due to the construction work.